San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

November 10, 2026

Mr. Samuel Nadores
Fresno/Clovis Regional WWTP
747 R St, 2nd Floor
Fresno, CA 39721

Re: Final – Authority to Construct / Certificate of Conformity (Minor Modification)
District Facility # C-535
Project # C-1261114

Dear Mr. Nadores:

The Air Pollution Control Officer has issued Authorities to Construct (C-535-59-0, '-60-0, and '-61-0) with Certificates of Conformity to Fresno/Clovis Regional WWTP at 5607 W Jensen Ave, Fresno, CA. The project was for the installation of three 3,629 bhp lean-burn natural gas-fired emergency standby IC engines powering electrical generators. Enclosed are the Authorities to Construct and a copy of the notice of final action that has been posted on the District's website (https://ww2.valleyair.org/).

Notice of the District's preliminary decision to issue the Authority to Construct permit was posted on September 24, 2026. The District's analysis of the proposal was also sent to CARB and US EPA Region IX on September 25, 2026. No comments were received following the District's preliminary decision on this project.

Also enclosed is an invoice for the engineering evaluation fees pursuant to District Rule 3010. Please remit the amount owed, along with a copy of the attached invoice, within 60 days.

Prior to operating with the modifications authorized by the Authority to Construct, you must submit an application to modify the Title V permit as an administrative amendment in accordance with District Rule 2520, Section 11.5. Application forms have been enclosed for your use. These forms may also be found on the District's website at https://ww2.valleyair.org/.

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

www.valleyair.org www.healthyairliving.com

Printed on recycled paper.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Errol Villegas, Permit Services Manager, at (559) 230-5900.

Sincerely,



Brian Clements
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email
cc: EPA Region 9 Air Permitting Manager (w/enclosure) via EPS

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

Facility # C-535
FRESNO/CLOVIS REGIONAL WWTP
5607 W JENSEN AVE
FRESNO, CA 93706-9458

AUTHORITY TO CONSTRUCT (ATC)

QUICK START GUIDE

1. **Pay Invoice**: Please pay enclosed invoice before due date.
2. **Modify Your Title V Permit**: Prior to operating the equipment authorized under this ATC, submit an application to modify your Title V permit. See application forms at https://ww2.valleyair.org/permitting/title-v-operating-permits/application-forms/.
3. **Fully Understand ATC**: Make sure you understand ALL conditions in the ATC prior to construction, modification and/or operation.
4. **Follow ATC**: You must construct, modify and/or operate your equipment as specified on the ATC. Any unspecified changes may require a new ATC.
5. **Notify District**: You must notify the District's Compliance Department, at the telephone numbers below, upon start-up and/or operation under the ATC. Please record the date construction or modification commenced and the date the equipment began operation under the ATC. You may NOT operate your equipment until you have notified the District's Compliance Department. A startup inspection may be required prior to receiving your Permit to Operate.
6. **Source Test**: Schedule and perform any required source testing. See https://ww2.valleyair.org/compliance/source-testing for source testing resources.
7. **Maintain Records**: Maintain all records required by ATC. Records are reviewed during every inspection (or upon request) and must be retained for at least 5 years. Sample record keeping forms can be found at https://ww2.valleyair.org/compliance/recordkeeping-forms.

By operating in compliance, you are doing your part to improve air quality for all Valley residents.

For assistance, please contact District Compliance staff at any of the telephone numbers listed below.

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

www.valleyair.org www.healthyairliving.com

Printed on recycled paper.

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: C-535-59-0 **ISSUANCE DATE:** 11/10/2026

LEGAL OWNER OR OPERATOR: FRESNO/CLOVIS REGIONAL WWTP
MAILING ADDRESS: 5607 W JENSEN AVE
FRESNO, CA 93706-9458

LOCATION: 5607 W JENSEN AVE
FRESNO, CA 93706

EQUIPMENT DESCRIPTION:
3,629 BHP (INTERMITTENT) CATERPILLAR MODEL G3520 LEAN-BURN NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

Brian Clements for

Brian Clements, Director of Permit Services
C-535-59-0 : 11/10/2026 7:23:21 AM -- BUSHT : Joint Inspection NOT Required

7. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
8. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
9. This IC engine shall be fired on Public Utility Commission (PUC) regulated natural gas only. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed any of the following limits: 0.5 g-NOx/bhp-hr, 0.033 g-PM10/bhp-hr, 1.31 g-CO/bhp-hr, or 0.36 g-VOC/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The percent load, engine output, and stack gas volumetric flow rate shall be used to convert engine emissions to a mass basis (g/bhp-hr). [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
12. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
14. Source testing to measure NOx, CO, and VOC emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 1081 and 2201, and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
15. Source testing to measure NOx, CO, and VOC emissions from this unit shall be conducted at least once every 8,760 hours of operation or 36 months, whichever comes first. [District Rules 1081 and 2201, and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District and EPA within 60 days after completion of the source test. [Rule District Rule 1081 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit
17. For emissions source testing, the arithmetic average of three 60-consecutive-minute test runs shall apply. Each test run shall be conducted within 10 percent of 100 percent peak (or the highest achievable) load. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. NOx, CO, and VOC emission concentrations shall be converted over to mass basis (g/bhp-hr) for demonstrating compliance with the limits specified in this permit. [40 CFR 60.4244] Federally Enforceable Through Title V Permit
18. The following methods shall be used for source testing: NOx (ppmv) - EPA Method 7E; CO (ppmv) - EPA Method 10; VOC (ppmv) - EPA Method 18, or 25A or 25B; stack gas oxygen - EPA Method 3 or 3A; stack gas velocity/volumetric flowrate - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4. Alternative test methods as approved by EPA and the District may be used to address the source testing requirements of this permit. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
19. All equipment shall be maintained in good operating condition and shall be operated in a manner consistent with good air pollution control practice to minimize emissions of air contaminants [District Rule 2201 and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
20. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
21. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
22. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 45 hours per calendar year. [District Rule 4702] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

23. Notification of the date construction of this engine commenced shall be submitted to the District and EPA and shall be postmarked no later than 30 days after such date as construction commenced. The notification shall contain the following information: 1) Name and address of the owner or operator; 2) The address of the affected source; 3) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement; 4) Emission control equipment; and 5) Fuel used. Notification of construction and copies of source test results shall be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). [40 CFR 60.4245] Federally Enforceable Through Title V Permit

24. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702] Federally Enforceable Through Title V Permit

25. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type and quantity of each fuel used, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. Quantity of fuel used shall be recorded in standard cubic feet using a non-resettable, totalizing mass or volumetric fuel flow meter or other APCO approved-device. [District Rules 2201, 4701, and 4702, and 40 CFR 60.4243 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2201 and 4702 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: C-535-60-0 **ISSUANCE DATE:** 11/10/2026

LEGAL OWNER OR OPERATOR: FRESNO/CLOVIS REGIONAL WWTP
MAILING ADDRESS: 5607 W JENSEN AVE
FRESNO, CA 93706-9458

LOCATION: 5607 W JENSEN AVE
FRESNO, CA 93706

EQUIPMENT DESCRIPTION:
3,629 BHP (INTERMITTENT) CATERPILLAR MODEL G3520 LEAN-BURN NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

Brian Clements for

Brian Clements, Director of Permit Services
C-535-60-0 : 11/10/2026 7:24:09 AM -- BUSHT : Joint Inspection NOT Required

7. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
8. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
9. This IC engine shall be fired on Public Utility Commission (PUC) regulated natural gas only. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed any of the following limits: 0.5 g-NOx/bhp-hr, 0.033 g-PM10/bhp-hr, 1.31 g-CO/bhp-hr, or 0.36 g-VOC/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The percent load, engine output, and stack gas volumetric flow rate shall be used to convert engine emissions to a mass basis (g/bhp-hr). [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
12. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
14. Source testing to measure NOx, CO, and VOC emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 1081 and 2201, and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
15. Source testing to measure NOx, CO, and VOC emissions from this unit shall be conducted at least once every 8,760 hours of operation or 36 months, whichever comes first. [District Rules 1081 and 2201, and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District and EPA within 60 days after completion of the source test. [Rule District Rule 1081 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit
17. For emissions source testing, the arithmetic average of three 60-consecutive-minute test runs shall apply. Each test run shall be conducted within 10 percent of 100 percent peak (or the highest achievable) load. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. NOx, CO, and VOC emission concentrations shall be converted over to mass basis (g/bhp-hr) for demonstrating compliance with the limits specified in this permit. [40 CFR 60.4244] Federally Enforceable Through Title V Permit
18. The following methods shall be used for source testing: NOx (ppmv) - EPA Method 7E; CO (ppmv) - EPA Method 10; VOC (ppmv) - EPA Method 18, or 25A or 25B; stack gas oxygen - EPA Method 3 or 3A; stack gas velocity/volumetric flowrate - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4. Alternative test methods as approved by EPA and the District may be used to address the source testing requirements of this permit. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
19. All equipment shall be maintained in good operating condition and shall be operated in a manner consistent with good air pollution control practice to minimize emissions of air contaminants [District Rule 2201 and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
20. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
21. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
22. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 45 hours per calendar year. [District Rule 4702] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

23. Notification of the date construction of this engine commenced shall be submitted to the District and EPA and shall be postmarked no later than 30 days after such date as construction commenced. The notification shall contain the following information: 1) Name and address of the owner or operator; 2) The address of the affected source; 3) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement; 4) Emission control equipment; and 5) Fuel used. Notification of construction and copies of source test results shall be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). [40 CFR 60.4245] Federally Enforceable Through Title V Permit

24. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702] Federally Enforceable Through Title V Permit

25. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type and quantity of each fuel used, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. Quantity of fuel used shall be recorded in standard cubic feet using a non-resettable, totalizing mass or volumetric fuel flow meter or other APCO approved-device. [District Rules 2201, 4701, and 4702, and 40 CFR 60.4243 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2201 and 4702 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit

San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

AUTHORITY TO CONSTRUCT

PERMIT NO: C-535-61-0 **ISSUANCE DATE:** 11/10/2026

LEGAL OWNER OR OPERATOR: FRESNO/CLOVIS REGIONAL WWTP
MAILING ADDRESS: 5607 W JENSEN AVE
FRESNO, CA 93706-9458

LOCATION: 5607 W JENSEN AVE
FRESNO, CA 93706

EQUIPMENT DESCRIPTION:
3,629 BHP (INTERMITTENT) CATERPILLAR MODEL G3520 LEAN-BURN NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

CONDITIONS

1. This Authority to Construct serves as a written certificate of conformity with the procedural requirements of 40 CFR 70.7 and 70.8 and with the compliance requirements of 40 CFR 70.6(c). [District Rule 2201] Federally Enforceable Through Title V Permit
2. Prior to operating with modifications authorized by this Authority to Construct, the facility shall submit an application to modify the Title V permit with an administrative amendment in accordance with District Rule 2520 Section 5.3.4. [District Rule 2520, 5.3.4] Federally Enforceable Through Title V Permit
3. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
4. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
5. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
6. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702]

CONDITIONS CONTINUE ON NEXT PAGE

YOU MUST NOTIFY THE DISTRICT COMPLIANCE DIVISION AT (559) 230-5950 WHEN CONSTRUCTION IS COMPLETED AND PRIOR TO OPERATING THE EQUIPMENT OR MODIFICATIONS AUTHORIZED BY THIS AUTHORITY TO CONSTRUCT. This is NOT a PERMIT TO OPERATE. Approval or denial of a PERMIT TO OPERATE will be made after an inspection to verify that the equipment has been constructed in accordance with the approved plans, specifications and conditions of this Authority to Construct, and to determine if the equipment can be operated in compliance with all Rules and Regulations of the San Joaquin Valley Unified Air Pollution Control District. Unless construction has commenced pursuant to Rule 2050, this Authority to Construct shall expire and application shall be cancelled two years from the date of issuance. The applicant is responsible for complying with all laws, ordinances and regulations of all other governmental agencies which may pertain to the above equipment.

Samir Sheikh, Executive Director / APCO

Brian Clements for

Brian Clements, Director of Permit Services
C-535-61-0 : 11/10/2026 7:24:28 AM -- BUSHT : Joint Inspection NOT Required

7. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702] Federally Enforceable Through Title V Permit
8. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702] Federally Enforceable Through Title V Permit
9. This IC engine shall be fired on Public Utility Commission (PUC) regulated natural gas only. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
10. Emissions from this IC engine shall not exceed any of the following limits: 0.5 g-NOx/bhp-hr, 0.033 g-PM10/bhp-hr, 1.31 g-CO/bhp-hr, or 0.36 g-VOC/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The percent load, engine output, and stack gas volumetric flow rate shall be used to convert engine emissions to a mass basis (g/bhp-hr). [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
12. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
14. Source testing to measure NOx, CO, and VOC emissions from this unit shall be conducted within 60 days of initial start-up. [District Rules 1081 and 2201, and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
15. Source testing to measure NOx, CO, and VOC emissions from this unit shall be conducted at least once every 8,760 hours of operation or 36 months, whichever comes first. [District Rules 1081 and 2201, and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
16. The results of each source test shall be submitted to the District and EPA within 60 days after completion of the source test. [Rule District Rule 1081 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit
17. For emissions source testing, the arithmetic average of three 60-consecutive-minute test runs shall apply. Each test run shall be conducted within 10 percent of 100 percent peak (or the highest achievable) load. If two of three runs are above an applicable limit, the test cannot be used to demonstrate compliance with an applicable limit. NOx, CO, and VOC emission concentrations shall be converted over to mass basis (g/bhp-hr) for demonstrating compliance with the limits specified in this permit. [40 CFR 60.4244] Federally Enforceable Through Title V Permit
18. The following methods shall be used for source testing: NOx (ppmv) - EPA Method 7E; CO (ppmv) - EPA Method 10; VOC (ppmv) - EPA Method 18, or 25A or 25B; stack gas oxygen - EPA Method 3 or 3A; stack gas velocity/volumetric flowrate - EPA Method 2 or EPA Method 19; stack gas moisture content - EPA Method 4. Alternative test methods as approved by EPA and the District may be used to address the source testing requirements of this permit. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
19. All equipment shall be maintained in good operating condition and shall be operated in a manner consistent with good air pollution control practice to minimize emissions of air contaminants [District Rule 2201 and 40 CFR 60.4243] Federally Enforceable Through Title V Permit
20. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
21. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
22. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 45 hours per calendar year. [District Rule 4702] Federally Enforceable Through Title V Permit

CONDITIONS CONTINUE ON NEXT PAGE

23. Notification of the date construction of this engine commenced shall be submitted to the District and EPA and shall be postmarked no later than 30 days after such date as construction commenced. The notification shall contain the following information: 1) Name and address of the owner or operator; 2) The address of the affected source; 3) Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement; 4) Emission control equipment; and 5) Fuel used. Notification of construction and copies of source test results shall be submitted electronically using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) (www.epa.gov/cdx). [40 CFR 60.4245] Federally Enforceable Through Title V Permit

24. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702] Federally Enforceable Through Title V Permit

25. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: the total hours of operation, the type and quantity of each fuel used, maintenance and modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. Quantity of fuel used shall be recorded in standard cubic feet using a non-resettable, totalizing mass or volumetric fuel flow meter or other APCO approved-device. [District Rules 2201, 4701, and 4702, and 40 CFR 60.4243 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 2201 and 4702 and 40 CFR 60.4245] Federally Enforceable Through Title V Permit