



July 18, 2023

Mr. Joel Lepoutre  
McKittrick Limited  
347549 Lencioni Ave  
Bakersfield, CA 93308

**Re: Notice of Final Action - Title V Permit Renewal**  
**Facility Number: S-1251**  
**Project Number: S-1212996**

Dear Mr. Lepoutre:

The District has issued the Final Renewed Title V Permit for McKittrick Limited (see enclosure). The preliminary decision for this project was made on May 2, 2023. No comments were received following the District's preliminary decision on this project.

The public notice for issuance of the Final Title V Permit will be posted on the District's website ([www.valleyair.org](http://www.valleyair.org)).

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Nick Peirce, Permit Services Manager, at (209) 557-6400.

Sincerely,

Brian Clements  
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email  
cc: Gerardo Rios, EPA (w/enclosure) via EPS

**Samir Sheikh**  
Executive Director/Air Pollution Control Officer

---

**Northern Region**  
4800 Enterprise Way  
Modesto, CA 95356-8718  
Tel: (209) 557-6400 FAX: (209) 557-6475

**Central Region (Main Office)**  
1990 E. Gettysburg Avenue  
Fresno, CA 93726-0244  
Tel: (559) 230-6000 FAX: (559) 230-6061

**Southern Region**  
34946 Flyover Court  
Bakersfield, CA 93308-9725  
Tel: (661) 392-5500 FAX: (661) 392-5585



**San Joaquin Valley**  
AIR POLLUTION CONTROL DISTRICT



# Permit to Operate

**FACILITY:** S-1251

**EXPIRATION DATE:** 03/31/2027

**LEGAL OWNER OR OPERATOR:**

MCKITTRICK LIMITED

**MAILING ADDRESS:**

34759 LENCIONI AVE  
BAKERSFIELD, CA 93308

**FACILITY LOCATION:**

HEAVY OIL WESTERN  
4905 REWARD RD  
MCKITTRICK, CA 93251

**FACILITY DESCRIPTION:**

COGENERATION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

**Samir Sheikh**

Executive Director / APCO

**Brian Clements**

Director of Permit Services

# San Joaquin Valley Air Pollution Control District

**FACILITY:** S-1251-0-6

**EXPIRATION DATE:** 03/31/2027

## **FACILITY-WIDE REQUIREMENTS**

---

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1]
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0]
3. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (8/18/2011). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040]
8. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
9. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
10. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: MCKITTRICK LIMITED

Location: HEAVY OIL WESTERN, 4905 REWARD RD, MCKITTRICK, CA 93251

S-1251-0-6 : Jul 18 2023 8:06AM -- PINEDAE

11. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
12. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
13. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
14. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
15. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
16. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
17. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
18. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
22. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

23. No person shall: manufacture, blend, or repackage for use within the District; or supply, sell, market or offer for sale within the District; or solicit for application or apply within the District any architectural coating or colorant with a VOC content in excess of the corresponding limit specified in Table 1 or Table 2 of District Rule 4601 (4/16/20), after the specified effective dates in Table 1 or Table 2 of District Rule 4601. [District Rule 4601] Federally Enforceable Through Title V Permit
24. All architectural coating containers and containers of any VOC-containing materials subject to District Rule 4601 (4/16/20) shall be closed when not in use. [District Rule 4601] Federally Enforceable Through Title V Permit
25. The permittee shall comply with all the Labeling and Test Methods requirements outlined in District Rule 4601, sections 6.1 and 6.3 (4/16/20). [District Rule 4601] Federally Enforceable Through Title V Permit
26. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
27. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
28. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
29. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
30. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
31. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
32. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
33. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
34. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
35. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

36. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
37. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
38. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVAPCD Rules 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
40. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan when mandated by the regulation. [40 CFR Part 68] Federally Enforceable Through Title V Permit
41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
42. The owners and operators of each affected source and each affected unit at the source shall: (i) Operate the unit in compliance with a complete Acid Rain permit application or a superceding Acid Rain permit issued by the permitting authority; and (ii) have an Acid Rain permit. [40 CFR 72] Federally Enforceable Through Title V Permit
43. The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75. [40 CFR 75] Federally Enforceable Through Title V Permit
44. The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program. [40 CFR 75] Federally Enforceable Through Title V Permit
45. The owners and operators of each source and each affected unit at the source shall: (i) hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and (ii) comply with the applicable Acid Rain emissions limitations for sulfur dioxide. [40 CFR 73] Federally Enforceable Through Title V Permit
46. Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act. [40 CFR 77] Federally Enforceable Through Title V Permit
47. An affected unit shall be subject to the sulfur dioxide requirements starting on the later of January 1, 2000, or the deadline for monitoring certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3) that is not a substitution or compensating unit. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
48. Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program. [40 CFR 72] Federally Enforceable Through Title V Permit
49. An allowance shall not be deducted in order to comply with the requirements under 40 CFR part 73, prior to the calendar year for which the allowance was allocated. [40 CFR 73] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE  
These terms and conditions are part of the Facility-wide Permit to Operate.

50. An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization. [40 CFR 72] Federally Enforceable Through Title V Permit
51. An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right. [40 CFR 72] Federally Enforceable Through Title V Permit
52. The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides. [40 CFR 72] Federally Enforceable Through Title V Permit
53. The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
54. The owners and operators of an affected unit that has excess emissions in any calendar year shall: (i) pay without demand the penalty required, and pay up on demand the interest on that penalty; and (ii) comply with the terms of an approved offset plan, as required by 40 CFR part 77. [40 CFR 77] Federally Enforceable Through Title V Permit
55. The owners and operators of the each affected unit at the source shall keep on site the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority: (i) The certificate of representation for the designated representative for the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site beyond such five-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative. [40 CFR 72] Federally Enforceable Through Title V Permit
56. The owners and operators of each affected unit at the source shall keep on site each of the following documents for a period of five years from the date the document is created. This period may be extended for cause, at any time prior to the end of five years, in writing by the Administrator or permitting authority; (ii) All emissions monitoring information, in accordance with 40 CFR part 75; (iii) Copies of all reports, compliance certifications and other submissions and all records made or required under the Acid Rain Program; (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission that demonstrates compliance with the requirements of the Acid Rain Program. [40 CFR 72, 40 CFR 75] Federally Enforceable Through Title V Permit
57. The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR 75 Subpart I. [40 CFR 75] Federally Enforceable Through Title V Permit
58. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

# San Joaquin Valley Air Pollution Control District

**PERMIT UNIT:** S-1251-1-13

**EXPIRATION DATE:** 03/31/2027

**SECTION:** NE13 **TOWNSHIP:** 30S **RANGE:** 21E

**EQUIPMENT DESCRIPTION:**

48 MW COGENERATION SYSTEM WITH SCR INCLUDING STEWART & STEVENSON GE LM 5000 GAS-FIRED TURBINE, HEAT RECOVERY STEAM GENERATOR, AND INLET AIR ABSORPTION CHILLER AND HEAT EXCHANGER

## PERMIT UNIT REQUIREMENTS

---

1. Maximum heat input rating of General Electric LM 5000 gas-fired turbine engine shall not exceed 457.8 MM Btu/hr, and turbine shall be equipped with combustor steam injection and selective catalytic reduction, utilizing ammonia, for NOx control. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Turbine engine combustor steam injection system shall be equipped with continuously recording steam to fuel injection rate monitoring system accurate to within +/- 5%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Unfired heat recovery steam generator shall not be designed for supplemental firing, and shall be equipped with continuously recording NOx, CO, and O2 monitors in exhaust stack. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Turbine engine shall be equipped with carbon monoxide reactor of sufficient catalyst volume to meet CO and VOC emissions limits. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Turbine lube oil reservoir shall be equipped with mist collectors with return line to the turbine lube oil reservoir. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Turbine air/oil separator shall be equipped with pre-separator, heat exchanger and air/oil final separator with return lines to turbine lube oil reservoir. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Generator lube oil reservoir shall be equipped with mist collector with return piping to generator lube oil reservoir. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Turbine shall be equipped with continuously recording fuel gas flowmeter and turbine shall utilize only natural gas as fuel. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Circular cross section exhaust stack (after SCR unit) shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods and equipped with flow straightener, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit
10. Ammonia injection grid shall be equipped with operational ammonia flowmeter and injection pressure indicator, and exhaust gas temperature at SCR catalyst inlet shall be monitored by operational temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Turbine engine steam injection rate shall be maintained at a steam to fuel ratio expected to result in compliance with emissions limits, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
12. All gas turbine engine exhaust shall flow through catalyst bed. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: MCKITTRICK LIMITED

Location: HEAVY OIL WESTERN, 4905 REWARD RD, MCKITTRICK, CA 93251

S-1251-1-13 : Jul 18 2023 8:06AM -- PINEDAE



13. Inlet gas temperature to catalyst bed shall be maintained within the range recommended by manufacturer except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
14. McKittrick Limited shall monitor and record exhaust gas temperature at oxidation catalyst inlet. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Ammonia injection rate shall be controlled to maintain ammonia slip of less than 20 ppmv. [District Rule 4102]
16. Fuel gas sulfur content shall not exceed 0.25 gr H<sub>2</sub>S/100 scf. [District Rules 2201 and 4801, Kern County Rule 407, and 40 CFR 60.333(a) & (b)] Federally Enforceable Through Title V Permit
17. Steam produced at this facility for use in oil production operations shall affect only wells connected to well vent vapor recovery systems approved by District. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Maximum VOC emission concentration (as CH<sub>4</sub>) at turbine exhaust shall not exceed 5.33 ppmv dry at 15% O<sub>2</sub>, except during periods of startup and shutdown. (BACT requirement, only if catalyst inlet temperature exceeds 800 deg F). [District Rule 2201] Federally Enforceable Through Title V Permit
19. VOC emissions, including emissions from turbine and generator lube oil vents, shall not exceed 5.5 lbs/hr, except during periods of startup and shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Emissions rate from turbine exhaust shall not exceed any of the following limits: 51.9 lbs PM<sub>10</sub>/day, 7.0 lbs SO<sub>x</sub> (as SO<sub>2</sub>)/day, 147.9 lbs NO<sub>x</sub>/day, 264 lbs CO/day, or 130.8 lbs VOC/day. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Emission concentration of oxides of nitrogen (as NO<sub>2</sub>) at turbine exhaust shall not exceed 3.75 ppmv dry calculated to 15% O<sub>2</sub> averaged over a three hour period, except during periods of startup or shutdown. [District Rules 2201 and 4703, 5.1, and 40 CFR 60.332(a)(1) & 60.332(a)(2)] Federally Enforceable Through Title V Permit
22. Emissions concentration of carbon monoxide at turbine exhaust shall not exceed 11 ppmv calculated to 15% O<sub>2</sub> averaged over a three hour period, except during periods of startup or shutdown. [District Rules 2201 and 4703, 5.1] Federally Enforceable Through Title V Permit
23. Compliance with NO<sub>x</sub> (ppmv), CO (ppmv), VOC (ppmv), turbine exhaust VOC (hourly), ammonia (ppmv) emissions limits, and lube oil cooler/accumulating vent opacity shall be demonstrated by District witnessed sample collection and observation annually. [District Rules 2201 and 4703] Federally Enforceable Through Title V Permit
24. Compliance with fuel gas sulfur content shall be demonstrated by fuel gas sample analysis at time of annual stack gas sampling. [District Rule 2201] Federally Enforceable Through Title V Permit
25. Any lube oil cooler/accumulating vent having visible emissions with an opacity of 5% or greater shall be tested to demonstrate compliance with VOC hourly emissions limit. Official test results/field data shall be submitted within 60 days of testing. [District Rule 1081] Federally Enforceable Through Title V Permit
26. A written record of the compliance demonstrations shall be maintained and made available for District inspection for a period of five years. [District Rules 2201 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
27. McKittrick Limited shall keep accurate records of daily fuel consumption of gas turbine engine and shall make records readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
28. The owner or operator shall certify, maintain, operate, and quality-assure a Continuous Emission Monitoring System (CEMS) which continuously measures and records the exhaust gas NO<sub>x</sub> and O<sub>2</sub> concentrations. [District Rule 4703, 6.2.1 and 40 CFR 60.334(b)] Federally Enforceable Through Title V Permit
29. The CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [District Rule 1080, 6.4 and 40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: MCKITTRICK LIMITED

Location: HEAVY OIL WESTERN, 4905 REWARD RD, MCKITTRICK, CA 93251

S-1251-1-13 : Jul 18 2023 8:06AM -- PINEDAE

30. The NO<sub>x</sub> and O<sub>2</sub> CEMS shall meet the requirements in 40 CFR 60, Appendix B Performance Specifications 2 and 3 and 40 CFR 60, Appendix F Procedure 1, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [District Rules 1080, 6.3, 6.5, 6.6, & 7.2 and 4703, and 40 CFR 60.334(b)(1)] Federally Enforceable Through Title V Permit
31. The CEMS shall be linked to a data logger which is compatible with the District's Data acquisition system. Upon notice by the District that the facility's CEM system is not providing polling data, the facility may continue to operate without providing automated data for a maximum of 30 days per calendar year provided the CEM data is sent to the District by a District-approved alternative method. [District Rule 1080, 7.1] Federally Enforceable Through Title V Permit
32. The owner or operator shall maintain CEMS records that contain the following: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance, duration of any periods during which a continuous monitoring system or monitoring device is inoperative, and emission measurements. [District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
33. The owner or operator shall submit a written report of CEM operations for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NO<sub>x</sub> emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative (monitor downtime), except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [District Rule 1080, 8.0 and 40 CFR 60.334(j), (j)(5)] Federally Enforceable Through Title V Permit
34. Excess emissions shall be defined as any operating hour in which 4-hour rolling average NO<sub>x</sub> concentration exceeds applicable emissions limit and a period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NO<sub>x</sub> or O<sub>2</sub> (or both). [40 CFR 60.334(j)(1)(iii)] Federally Enforceable Through Title V Permit
35. APCO or an authorized representative shall be allowed to inspect, as determined to be necessary, the monitoring devices required by this rule to ensure that such devices are functioning properly. [District Rule 1080, 11.0] Federally Enforceable Through Title V Permit
36. Reduced Load Period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.19] Federally Enforceable Through Title V Permit
37. Thermal Stabilization Period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
38. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
39. The sulfur content of each fuel source shall be: (i) documented in a valid purchase contract, a supplier certification, a tariff sheet or transportation contract or (ii) monitored weekly using ASTM Methods D4084, D5504, D6228, or Gas Processors Association Standard 2377. If H<sub>2</sub>S content is less than 0.25 gr/100 scf for 8 consecutive weeks, then the Monitoring frequency shall be every six (6) months. If any six (6) month monitoring show an exceedance, weekly monitoring shall resume. [District Rule 2520, 9.3.2 and 40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit
40. Performance testing shall be conducted annually to measure NO<sub>x</sub> and CO emission concentrations using the following test methods: EPA Methods 7E or 20 for NO<sub>x</sub> emissions, EPA Methods 10 or 10B for CO emissions, EPA Methods 3, 3A, or 20 for Oxygen content of the exhaust gas. The 9-run tests shall be performed at between 90 and 100 percent of peak load (or the highest physically achievable load) of the gas turbine. [District Rule 4703, 6.3.1, 6.4.1, 6.4.2, & 6.4.3 and 40 CFR 60.335(a), (b)(7)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: MCKITTRICK LIMITED

Location: HEAVY OIL WESTERN, 4905 REWARD RD, MCKITTRICK, CA 93251

S-1251-1-13 : Jul 18 2023 8:06AM -- PINEDAE

41. The owner or operator shall be required to conform to the sampling facilities and testing procedures described in District Rule 1081, 3.0, & 6.0 (as amended 12/16/93). [District Rule 1081, 3.0 & 6.0] Federally Enforceable Through Title V Permit
42. The District must be notified 30 days prior to any performance testing and a test plan shall be submitted for District approval 15 days prior to such testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
43. Performance testing shall be witnessed or authorized District personnel. Test results must be submitted to the District within 60 days of performance testing. [District Rule 1081, 7.2, 7.3] Federally Enforceable Through Title V Permit
44. The owner or operator of a stationary gas turbine system shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rules 2520, 9.4.2 and 4703, 6.2.4] Federally Enforceable Through Title V Permit
45. Results of the CEM system shall be averaged over a three hour period, using consecutive 15-minute sampling periods in accordance with all applicable requirements of CFR 60.13. [District Rule 4703, 5.1, 6.4 and 40 CFR 60.13] Federally Enforceable Through Title V Permit
46. Owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local time start-up and stop time, length and reason for reduced load periods, total hours of operation, type and quantity of fuel used. [District Rule 4703, 6.2.6] Federally Enforceable Through Title V Permit
47. Compliance with the ammonia slip (ppmv) emission limits shall be demonstrated by sample collection taken by independent testing laboratory annually within 60 days prior to permit anniversary date. The District shall be notified prior to the completion of any sampling event. Official test results and field data collection shall be submitted to the District within 60 days of testing. [District Rule 4102]
48. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Kern County Rule 407. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
49. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.332 (a)(1), (a)(2), 60.333 (b); 60.334(b) (b)(1), (b)(2), (h)(3), (j), (j)(1)(iii), and (j)(5), and 60.335(a), (b)(7), (b)(3), and District Rule 4703 (as amended 9/20/07), Sections 5.1.2.1, 5.2, 6.2.2, 6.2.6, 6.3, and 6.4. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
50. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: 40 CFR 60.7(b) and 60.13, and District Rules 1080 (as amended 12/17/92), Sections 6.3, 6.4, 6.5, 6.6, 7.1, 7.2, 7.3, 8.0, and 11.0; 1081(as amended 12/16/93), Sections 3.0, 6.0, 7.1, 7.2, and 7.3; and 4201 (as amended 12/17/92). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.